



METER SPREAD TABLE		
METER SIZE	FEMALE THREADED REDUCER	DISTANCE OF SPREAD
5/8"	1" TO 3/4"	12" WITHOUT COUPLINGS
1"	N/A	15" WITHOUT COUPLINGS

N.T.S.

PRIOR TO INSTALLATION:

- ✓ METERS CANNOT BE INSTALLED IN CRAWL SPACES, BEHIND APPLIANCES, HOT WATER HEATERS OR FURNACES.
- ✓ THERE MUST BE A MINIMUM CLEARANCE OF 12" ON EACH SIDE OF THE METER AND A MAXIMUM OF 36" ABOVE THE FLOOR.

IN ADVANCE OF THE PROJECTED INSTALLATION DATE, CONTACT CUSTOMER SERVICE:

- ✓ AN APPLICATION FOR SERVICE MUST BE COMPLETED.
- ✓ APPLICABLE CONNECTION FEES MUST BE PAID IN ACCORDANCE WITH THE CURRENT 'SCHEDULE OF RATES'.
- ✓ AN APPOINTMENT IS SCHEDULED FOR WATER METER INSTALLATION, GRANTED ALL CONNECTION FEES HAVE BEEN SATISFIED.
- ✓ ALL METERS ARE SUPPLIED BY THE AUTHORITY. (METERS 1 1/2 INCHES OR LARGER ARE INSTALLED BY THE CONTRACTOR BUT INSPECTED BY AUTHORITY PERSONNEL. METERS SMALLER THAN 1 1/2 INCHES WILL BE INSTALLED BY AUTHORITY PERSONNEL.)

AT THE TIME OF THE INSTALLATION:

- ✓ CURB STOPS AND SEWER CLEAN-OUTS ARE NOT PERMITTED IN DRIVEWAYS OR SIDEWALKS AND MUST BE SET TO GRADE BEFORE THE METER CAN BE INSTALLED.
- ✓ A TUB AND/OR SINK MUST BE INSTALLED IN ORDER TO FLOW TEST THE METER.
- ✓ NEW CONSTRUCTION MUST HAVE HEAT.

NOTE: IF THE METER SPREAD OR OTHER REQUIREMENTS ARE NOT MET, AN ADDITIONAL FEE, IN ACCORDANCE WITH THE CURRENT 'SCHEDULE OF RATES' WILL BE APPLIED TO THE ACCOUNT AND MUST BE PAID IN FULL BEFORE A SECOND INSTALLATION IS ATTEMPTED.

AFTER THE INSTALLATION:

- ✓ ONCE THE AUTHORITY HAS DETERMINED THAT THE METER HAS BEEN SUCCESSFULLY INSTALLED AND TESTED, CUSTOMER SERVICE WILL ISSUE A LETTER OF COMPLIANCE FOR PRESENTATION TO THE TOWNSHIP.

SINGLE WATER METER

JACKSON TOWNSHIP M.U.A.

NO.	DATE REVISED
5	
4	
3	
2	APRIL 2011
1	MARCH 2010
DRAWN FEB 2003	
SHEET	1 OF 20

