


SEAL WITH NON-SHRINKING GROUT



CONCRETE & RUBBER GASKET JOINT SHALL BE IN ACCORDANCE WITH A.S.T.M. SPEC C-361 & C-443 & BE WATERTIGHT AT HEAD PRESSURES UP TO 50'

DETAIL A

"Y" BRANCH P.V.C. SDR-35

FLOW

POURED IN PLACE TO BE CONSTRUCTED IN FIELD

3000 PSI CONCRETE

NOTES

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CONSTRUCTING ADEQUATE BALLASTS TO OFFSET FLOTATION FORCES ACTING ON MANHOLES
2. ALL REINFORCEMENT IS SUBJECT TO ENGINEERS APPROVAL BEFORE CONSTRUCTION

N.T.S.

DROP MANHOLE

JACKSON TOWNSHIP M.U.A.

NO.	DATE REVISED
5	
4	
3	
2	
1	MARCH 2010
DRAWN FEB 2003	
SHEET	14 OF 20

