



1. CONCRETE SHALL ATTAIN A MINIMUM COMPRESSION STRENGTH OF 4000 PSI @ 28 DAYS
2. REINFORCING STEEL SHALL BE GRADE 60
3. LID SHALL BE FORD RM STYLE

FOR 1 1/2" METERS OR LARGER

# METER PIT

## JACKSON TOWNSHIP M.U.A.

NO.	DATE REVISED
5	
4	
3	
2	
1	MARCH 2010
DRAWN FEB 2003	
SHEET	4 OF 20

