



N.T.S.

1. ANY VALVE (WATER OR FORCE MAIN) INSTALLED OUTSIDE OF ASPHALT AREAS MUST BE CONSTRUCTED WITH A 2'x2'x6" CONCRETE COLLAR AROUND IT.

# WATER MAIN VALVE

## JACKSON TOWNSHIP M.U.A.

| NO.   | DATE REVISED   |
|-------|----------------|
| 5     |                |
| 4     |                |
| 3     |                |
| 2     | APRIL 2011     |
| 1     | MARCH 2010     |
|       | DRAWN FEB 2003 |
| SHEET | 8 OF 20        |

